



**SJÖFARTSVERKET**  
Sjöfartsinspektionen

Executive officer, direct phone

Krister Ingvarson, 011-19 12 93

Swedish Maritime Administration

Date

1997-02-04

Our denomination

010203-9770000

Your date

1996-10-22

Your denomination

· Olle Termén Consulting AB

Linnégatan 1  
S-35233 VÄXJÖ

## APPROVAL OF FOGMAKER WATER MIST EXTINGUISHER

Hereby is certified that Your 3.3 litre water mist system type

### FOGMAKER

is approved for installation in the engine room in pleasure boats with a gross volume of maximum 5 m<sup>3</sup>.

The approval is based on tests performed by Sveriges Provnings- och forskningsinstitut, Borås and is declared in report no 96 R30737b, dated 1996-09-24.

The Fogmaker system is built up by the following parts:

1. Pressurised container with extinguishant
2. Release valve
3. Activation device
4. Pipes, couplings and nozzles

The set-up can be arranged with automatic or manual release.

The system must only be installed in engine rooms with a greatest height of 1,5 m. Nozzles shall be installed at a maximum distance of 0,45 m to bulkhead or wall and with a maximum distance of 0,9 m between the nozzles.

A description of the system, directions for installation, use of the set-up and actions in case of a fire shall be delivered together with the set-up.

Krister Ingvarson

Department of ship technology